

## Heaters, Air for Use in Hazardous Locations

See General Information for Heaters, Air for Use in Hazardous Locations

### **CHROMALOX INC**

103 Gamma Dr  
Pittsburgh, PA 15238 USA

E32299

Trademark and/or Tradename: "Etirex"

#### **Class I, Groups B, C and D.**

Convection-type electric heaters for wall mounting , Cat. No. CVEP, with or without a suffix letter, followed by 16, 18, 32, 36, 40, 45, 76 or 90, may be followed by a W, followed by 1, 2, 3, 4, 5, 6, 7, 8 or 9, followed by 1 or 3, followed by 00, 30, 31, 32, 33, 34, 35, 36 or 37, followed by 00 or 40, may be followed by -T3.

#### **Class I, Groups C and D, Class II, Groups F and G.**

Fan-type electric heater for ceiling or wall mounting, Cat. No. CXH with or without a suffix letter, followed by 03 thru 35, may be followed by W, 21, 221, 23, 33, 403, 443, 463, 43, 53, 63, 81, 83 or 93, followed by 00, 30 or 32, followed by 00 or 40, followed by 3 or 4, followed by 0, 1, 2, 3, 4, 5, 6, 7, 8, or 9, may be followed by CR, followed by EP. Minimum clearance: 4 in. to ceiling, 4 in. to sides, 8 in. to rear from motor. For supply connections, use copper wire suitable for 90 C.

#### **Class I, Groups C and D.**

Convection-type electric heaters for wall mounting , Cat. No. CVEP, with or without a suffix letter, followed by 16, 18, 32, 36, 40, 45, 76 or 90, may be followed by a W, followed by 1, 2, 3, 4, 5, 6, 7, 8 or 9, followed by 1 or 3, followed by 00, 30, 31, 32, 33, 34, 35, 36 or 37, followed by 42, may be followed by -T3.

Fan-type electric heater for wall or ceiling mounting, Cat. No. CXH with or without a suffix letter, followed by 03 through 35, may be followed by W, may be followed by S, M, or L, followed by 21, 23, 221, 33, 403, 443, 463, 43, 53, 63, 81, 83 or 93, may be followed by 5 or 6, followed by 30 or 32, followed by 00 or 40, followed by 1 or 2, followed by 0, may be followed by CR, followed by CE.

#### **Class I, Group D; Class II, Groups E, F and G.**

Fan-type electric heater for ceiling or wall mounting, Cat. No. CXH with or without a suffix letter, followed by 03 thru 35, may be followed by W, followed by 21, 221, 23, 33, 403, 443, 463, 43, 53, 63, 81, 83 or 93, followed by 00, 30 or 32, followed by 00 or 40, followed by 5 or 6, followed by 0, 1, 2, 3, 4, 5, 6, 7, 8, or 9, may be followed by CR, followed by EP. Minimum clearance: 4 in. to ceiling, 4 in. to sides, 8 in. to rear from motor. For supply connections, use copper wire suitable for 90 C.

#### **Class I, Group D.**

Convection-type electric heaters for wall mounting , Cat. No. CVEP, with or without a suffix letter, followed by 16, 18, 32, 36, 40, 45, 76 or 90, may be followed by a W, followed by 1, 2, 3, 4, 5, 6, 7, 8 or 9, followed by 1 or 3, followed by 00, 30, 31, 32, 33, 34, 35, 36 or 37, followed by 44, may be followed by -T3.

#### **Class I, Groups C and D; Class II, Groups E, F and G.**

W=Suffix used at end of catalog number when wattage is less than 3000 w.

Fan-type electric heater for ceiling or wall mounting, Cat. No. CXH with or without a suffix letter, followed by 03 thru 35, may be followed by W, followed by 21, 221, 23, 33, 403, 443, 463, 43, 53, 63, 81, 83, or 93, followed by 00, 30 or 32, followed by 00 or 40, followed by 1 or 2, followed by 0, 1, 2, 3, 4, 5, 6, 7, 8, or 9, may be followed by CR, followed by EP. Minimum clearance: 4 in. to ceiling, 4 in. to sides, 8 in. to the rear of the motor. For supply connections use wire suitable for 90 C.

Last Updated on 2017-07-24

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."