Controls

weather TRACE

FPLS

Freeze Protection Heat Trace Panels

(cont'd.)

Ordering Information

To Order — Complete the Model Number using the Matrix provided.

|--|

FPLS series Line Sensing Heat Trace Panels are designed for use in industrial Freeze Protection and Snow Melt applications. The Chromalox FPLS series offers the following standard features: NEMA 4 enclosure, Main Power On Lamp and Thermal Magnetic Branch Circuit Breakers with 30mA Ground Fault Equipment Protection. Options include: NEMA 4X 304 Stainless Steel Enclosures, Main Disconnect Switch, Enclosure Heater, and Type Z Pressurization System. The FPLS series panels have UL and cUL Third Party Approvals.

<u>(</u>	Code	Panelb	oard				Availabl	e Breaker Poles	
	12 20 30 42	20 Pos 30 Pos	itions (10) itions (22)	0 Amp M 5 Amp M	lain Rating lain Rating lain Rating lain Rating))	(20) 1-p (30) 1-p	ole breakers or (6) 2-pole B ble breakers or (10) 2-pole ble breakers or (14) 2-pole ble breakers or (20) 2-pole	Breakers Breakers
	Ī	Code Line Voltage				,		ater Load	Breaker Poles
		1 2 3 4	208/120 208/120	120 Vac 208/120 Vac 3-Phase, 4-Wi 208/120 Vac 3-Phase, 4-Wi 240-120 Vac 3-Phase			120 200 24) Vac) Vac 3 Vac (240 Vac Cable)) Vac odes 12 & 20), 60"H x 36"	1 1 2 2 2 W x 10"D (Codes 30 & 42)
			1 2 3	NEMA ·	4X Single-	Door, S	tainless S	ount Enclosure teel Wall-Mount Enclosure teel Wall-Mount Enclosure	
				Code	Ground	Fault B	ranch Circ	uit Breaker (see table for ma	ximum number of circuit breakers allowed
				1(*) 2(*) 3(*) 4(*) 5(*) 6(*) 7(*) 8(*)	20 Amp 25 Amp 30 Amp 15 Amp 20 Amp 25 Amp	1-Pole 1-Pole 1-Pole 2-Pole 2-Pole 2-Pole	GFI Circui GFI Circui GFI Circui GFI Circui GFI Circui GFI Circui	t Breaker for 120 Vac load t Breaker for 208/240 Vac l t Breaker for 208/240 Vac l t Breaker for 208/240 Vac l t Breaker for 208/240 Vac l	oad oad
				Ì	Code	Main I	Disconnec	t Switch Selection	
					0 1 2		np with 6	5k Fault Protection (Code 1: 5k Fault Protection (Code 3: ure Heater	
						0		ostat Controlled Enclosure I	
							Code	Pressurization Control S	ystem
							0 1	None Type Z Class 1, Division 2	2
S	20	1	1	1(4)	1	0	0	Typical Model Number (FPI S-20111(4)100)

Technical Notes:

(*) Enter number of circuit breakers in parenthesis

Note: Maximum number of circuit breakers is dependent on the panelboard size (see panelboard selection) and the current capacity of the panelboard (see table below)

100 Amp Panel Board	Breaker Rating				225 Panel Board	Breaker Rating			
	Maximum Number of Breakers					Maximum Number of Breakers			
Line Voltage	15 Amp	20 Amp	25 Amp	30 Amp	Line Voltage	15 Amp	20 Amp	25 Amp	30 Amp
Code 1 (1 Pole CB)	16	12	10	8	Code 1 (1 Pole CB)	37	28	22	18
Code 2 (1 Pole CB)	20	18	15	12	Code 2 (1 Pole CB)	42	42	33	28
Code 3 (2 Pole CB)	10	10	8	7	Code 3 (2 Pole CB)	20	20	19	16
Code 4 (2 Pole CB)	8	6	5	4	Code 4 (2 Pole CB)	18	14	11	9



weatherTRACE**

Freeze Protection Heat Trace Panels (cont'd.)

Ordering Information

To Order — Complete the Model Number using the Matrix provided.

Model	FPLA 277 Vac 4-Wire
FPLS	FPLS Series Line Sensing Heat Trace Panels are designed for use in Freeze Protection and Snow Melt applications
	malox FPLS series offers the following standard features: NEMA 4 enclosure, Main Power On Lamp, and Thermal

ns. The Chroal Magnetic Branch Circuit Breakers with 30mA Ground Fault Equipment Protection. Options include: NEMA 4X 304 Stainless Steel Enclosures, Main Disconnect Switch, Enclosure Heater, and Type Z Pressurization System. The FPLS series panels have UL and cUL Third Party Approvals.

Code	Panell	board				Avai	ilable Breaker Poles	
181	18 Pos	sitions (10	00 Amp Main Rating) 00 Amp Main Rating)		ng)	(8) 1-pole breakers		
301	30 Pos	sitions (10			ng)	(14)	1-pole breakers	
421		,	0 Amp Main Rating)			\ ,	1-pole breakers	
302		sitions (22			0,	` '	1-pole breakers	
422	42 Pos	sitions (22	25 Amp N	/lain Ratii	ng)	(20)	1-pole breakers	
	Code	Power	Source				Load Voltage	
	1	3 Phas	e Power,	277/480) Vac 4-Wi	ire	277 Vac (240 Vac Cable)	
		Code	Enclos	ure 48"H	l x 36"W x	10"D (Cod	des 12 & 20), 60"H x 36"W x 10"D (Codes 30 & 42)	
		1		- 3	,		nt Enclosure	
		2		U	,		el Wall-Mount Enclosure (Codes 12 & 20)	
		3	NEMA	4X Single	-Door, Sta	inless Stee	el Wall-Mount Enclosure (Codes 30 & 42)	
			Code	Ground	d Fault Bra	anch Circui	it Breaker (see table for maximum number of circuit breakers allo	
			1(*)	15 Am	n 1-Pole (GFI Circuit	Breaker for 277 Vac load	
		Breaker for 277 Vac load						
			2(*) 3(*)				Breaker for 277 Vac load	
				Code	Main D	isconnect	Switch Selection	
				0	None			
				1		ום with 25k	k Fault Protection (Code 181, 301 & 421 Only)	
				2			k Fault Protection (Code 302 & 422)	
					Code	Enclosur	re Heater	
					0	None		
					1	Thermos	stat Controlled Enclosure Heater	
						Code	Pressurization Control System	
						0	None	
						1	Type Z Class 1, Division 2	
124			1(1)					
181	2	1	1(4)	1	1	0	Typical Model Number (FPLS-181211(4)110)	

Technical Notes:

(*) Enter number of circuit breakers in parenthesis

Note: Maximum number of circuit breakers is dependent on the panelboard size (see panelboard selection) and the current capacity of the panelboard (see table below)

Breaker Rating								
	um Number of E	of Breakers						
277 Vac	15 Amp	15 Amp 20 Amp						
100 amp Panel B	20	18	12					
225 amp Panel B	20	20	20					

